



CITY OF LAGUNA HILLS SMOKE DETECTOR AND CARBON MONOXIDE SELF CERTIFICATION

Project Address: _____

Permit Number: _____

Property Owner: _____

I, the undersigned, hereby certify that I am the owner of the above referenced property. I further certify and acknowledge that smoke alarms and carbon monoxide alarms shall be installed and functional in all the following locations (Notes: All boxes below must be checked; retrofitted smoke detectors may be battery operated.)

- ☐ Smoke Alarms and Carbon Monoxide Alarm: On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of bedrooms or in each hallway outside of the rooms.
- ☐ Smoke Alarms: In each room used for sleeping purposes.
- ☐ Smoke Alarm and Carbon Monoxide Alarm: In each story, including any habitable basement. (Note: In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm and a carbon monoxide detector installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.)

Signature: _____ Date: _____

California Residential Code (CRC) Section R314.1, CRC R315.2 states in part that existing dwellings be "...retrofitted with smoke detectors and carbon monoxide detectors when a building permit is issued for, worked on or in a building that is valued at \$1,000 or more." CRC Section R314.3, CRC R315.3 defines required locations as indicted above.

NOTE: This Certification is commonly used for projects such as re-roofing, re-siding, patio covers, swimming pools, A/C condensers, and the like.



CITY OF LAGUNA HILLS SMOKE DETECTOR AND CARBON MONOXIDE SELF CERTIFICATION

PLACE ONE SMOKE ALARM ON EVERY FLOOR AND SLEEPING ROOM




MULTI-STORY



Carbon Monoxide
Detector

Smoke
Detector

SINGLE LEVEL



Alarms shall be installed at a
minimum distance of 3 feet
from fans and vents.